



MUNICIPAL CORPORATION CHANDIGARH
Public Health Laboratory at Water Works Sector 39.

TEST - REPORT

Ref. No. & Date

Issued to

Quantity of sample
Date of Collection
Client reference
Packing of sample
Source of sample

No. GMHS/48/SP-I Dated 19.06.2020
The Head mistress,
Govt Model High School,
Sector-48-D, Chandigarh.
Approximate 1200 ml.
23.06.2020
Sample collected by Laboratory Staff.
Sample filled in P.P. and Glass Bottle.
from School Tap of Govt Model High School,
Sector-48-D, Chandigarh.

No. Examination	Quality Standard	Units	Results
1. Turbidity	<1.0	N.T.U	1.0
2. pH	7.0-8.5	---	7.79
3. Residual Chlorine	0.2 - 0.4	mg/L	0.2
4. Total Alkalinity (as CaCO ₃)	200	-do-	80
5. Total Hardness (as CaCO ₃)	200	-do-	72
6. Chlorides (as Cl)	200	-do-	04
7. Free & Saline Ammonia	Nil	-do-	Nil
8. Total Dissolved Solids	500	-do-	130
9. M.P.N. of Coliform Bacilli	Zero	M.P.N.	0
Quality of water			(Excellent)

Amount received vide book receipt No.3806 09, dated 22.06.2020, Amount Rs.3300-

Water is fit for drinking.

Lab. No. MCPHL/20/ 2293

Dated:-26.06.2020

[Signature]
Chemist
MCPH Laboratory
Chandigarh

[Signature]
Sub Divisional Engineer,
M.C.P.H. Sub Division No.2,
Chandigarh. 26/6/20

Dated:-

Endst. No. MCPHL/20/

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh with reference to your letter Endst. No. MOH/Supdt. Admn./2019/4199 Dated 21.08.2019

[Signature]
Chemist
MCPH Laboratory
Chandigarh

[Signature]
Sub Divisional Engineer,
M.C.P.H. Sub Division No. 2,
Chandigarh